

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 4485-1336:100 Page 1 of 1

CATEGORY: Opening Protection (Firestopping)

LISTEE: A/D Fire Protection, 420 Tapscott Rd., Scarborough, Ontario, Canada
Contact: Don Falconer (416) 292-2361 FAX (416) 298-5887*

DESIGN: FIREBARRIER mineral wool, mortar, seal, silicone sealant (SL) and RTV foam. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Hourly fire rating, Warnock Hersey or UL label.

APPROVAL: Listed as 1, 2, and 3 hour fire-rated firestopping. Approval for Warnock Hersey Designs AD/PV 60-01 and 120-01 and UL Designs WL-1050, WL-3042, WL-5031, WL-8005, FC-1011, FC-3014 and FC-5007. Complete product description and application may be found in the current Warnock Hersey Certification Listings and UL Fire Resistance Directory.

*Rev. 06-05-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 22, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager